

Howard County Pipe Break Field Data

| Location and Contact information | | | |
|----------------------------------|--|---------------------|--------------|
| Date | 11/16/2012 | Time | 10:00 |
| Crew Leader name | Mike Fisher | Crew Leader phone # | 301-401-3680 |
| Address | 3205 Hearthstone road Ellicott city MD 21043 | | |
| ADC page | 4815 | ADC Grid | E6 |
| Base Map # | 3341 | Contract # | 88-w |

Soil Type

| Type | Check box | Type | Check box |
|------|-----------|----------------|-----------|
| Clay | | Clay/sand | |
| Sand | x | Blue/gray clay | |
| Silt | x | | |

Pipe Type

| Type | Check box | Type | Check box |
|--------------|-----------|----------------------|-----------|
| Cast iron | x | PCCP/Concrete | |
| Ductile iron | | Plastic PVC | |
| Steel | | Plastic polyethylene | |
| AC/Transite | | | |

Type of Break

| Type | Check box | Type | Check box |
|--------------|-----------|------------------|-----------|
| Circular | x | Damage by others | |
| Split | | Pipe Joint leak | |
| Pitting | | Valve problem | |
| Fitting leak | | Clamp repair | |

Size of Pipe

| | |
|----------------|----|
| Size in inches | 6" |
|----------------|----|