Howard County Department of Public Works Meadowridge Road Water Main Corrosion Study Capital Project W-8206

TABLE 2
Stray Current (Rosette) Test Data

Direction	Station Number		
	50+88	68+88	86+88
0 Dearees (North)	8.5	-4.8	1.6
45 Degrees (Northeast)	14.9	4.9	12.6
90 Degrees (East)	15.5	12.1	16.2
135 Degrees (Southeast)	9.5	22.4	13.6
180 Degrees (South)	10.0	21.9	4.1
225 Degrees (Southwest)	9.3	18.1	6.9
270 Degrees (West)	17.4	3.5	-1.0
315 Degrees (Northwest)	1.1	11.1	1.5
RESULTANT	8.7	44.6	30.6
DIRECTION (Degrees)	293.6	351.9	283.3

Page 22