

Howard County Pipe Break Field Data

Location and Contact information			
Date	4-13-11	Time	11:30 a.m.
Crew Leader name	D Borzell	Crew Leader phone #	410-313-4800
Address	6673 Pinch Rd.		
ADC page	4936	ADC Grid	E-10
Base Map #	37-	Contract #	950

Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	<input checked="" type="checkbox"/>
Sand		Blue/gray clay	
Silt			

Pipe Type

Type	Check box	Type	Check box
Cast iron	<input checked="" type="checkbox"/>	PCCP/Concrete	
Ductile iron		Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

Type of Break

Type	Check box	Type	Check box
Circular		Damage by others	
Split	<input checked="" type="checkbox"/>	Pipe Joint leak	
Fitting leak		Valve problem	

Size of Pipe

Size in inches	6"
----------------	----

118
11265
2000