

## Howard County Pipe Break Field Data

Location and Contact information			
Date	10-26-12	Time	10:00 AM
Crew Leader name	Duane Bozzell	Crew Leader phone #	410-313-4900
Address	7275 WATERLOO Rd		
ADC page	5054	ADC Grid	E3
Base Map #	22-44	Contract #	792

### Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	<input checked="" type="checkbox"/>
Sand		Blue/gray clay	
Silt			

### Pipe Type

Type	Check box	Type	Check box
Cast iron	<input type="checkbox"/>	PCCP/Concrete	
Ductile iron	<input checked="" type="checkbox"/>	Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

### Type of Break

Type	Check box	Type	Check box
Circular		Damage by others	
Split	<input checked="" type="checkbox"/>	Pipe Joint leak	
Fitting leak		Valve problem	

### Size of Pipe

Size in inches	10"
----------------	-----