

Howard County Pipe Break Field Data

	Location and Contact information		
Date	1-18-12	Time	2:30 PM
Crew Leader name	Tom Puchett	Crew Leader phone #	
Address	@ Meadow Ridge Pumping station		
ADC page	5054	ADC Grid	H-1
Base Map #	G-37-24-45	Contract #	713

Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	
Sand	<input checked="" type="checkbox"/>	Blue/gray clay	
Silt			

Pipe Type

Type	Check box	Type	Check box
Cast iron	<input checked="" type="checkbox"/>	PCCP/Concrete	
Ductile iron		Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

Type of Break

Type	Check box	Type	Check box
Circular		Damage by others	
Split		Pipe Joint leak	
Fitting leak	<input checked="" type="checkbox"/>	Valve problem	

SADDLE

Size of Pipe

Size in inches	16
----------------	----

Water Main and Service to be upgraded in 2 Days