

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS  
CORROSION CONTROL TEST STATION  
FIELD DATA SURVEY FORM**

Location: 19+33 Date Surveyed: 05/29/2007  
 Old Columbia Rd Surveyed by: AS/MJ  
 T/S #: 3a Contract #: 44-3868  
 T/S Type: ST w/Anode Pipe Size: 16"  
 Was the T/S located? YES / NO YES

**TEST STATION CONDITION**

Test Box:	Good
Terminal Board:	Good – Slightly covered with soil
Wires:	Good
Other:	

**SURVEY DATA**

Test Wire Size/Description	Color	P/Cu-CuSO <sub>4</sub> (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1. #10 AWG	Blue	-1.062	-0.830	-1.040	-0.928	55
2. #10 AWG	Black	-0.038	-0.020			
3.						
4. #6 AWG	Black	-1.110	-1.531	-1.568	-1.644	
5. #10 AWG	Blue	-1.061	-0.876	-1.140	-0.922	
6.						
7.						
8.						

P/Cu-CuSO<sub>4</sub> = Pipe to Copper-Copper Sulfate Reference Electrode

P/Zn = Pipe to Zinc Reference Electrode

"On" = Reading with Anode(s) connected

"Off" = Reading with Anode(s) disconnected

Anode = Current output Anode(s)

**TESTING THE EFFECTIVENESS OF INSULATING JOINTS**

Groundbed:			
Connected to (B/W):			
	Current (A)	Voltage (V)	Resistance (ohms)
ON:			
OFF:			
DELTA:			

**TESTING IR DROP**

IR Drop Calibrations	I (A)	E (mV)	$K = \frac{\Delta I \text{ (mA)}}{\Delta E \text{ (mV)}}$	Between Terminals	Resistance (ohms)
INITIAL:					
FINAL:					
DELTA:					
			Direction:		

**REPAIRS MADE**

Test Box:	
Terminal Board:	
Wires:	
Other:	
Comments/Recommendations:	



Figure 76 – Location of Test Station 3A - Old Columbia Road



Figure 77 – Test Station 3A close up