

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
CORROSION CONTROL TEST STATION
FIELD DATA SURVEY FORM**

Location: Lincoln Dr. & Cedar Ave. Date Surveyed: 06/13/2007
 T/S #: 02 Surveyed by: AS/MJ
 T/S Type: IJ Contract #: 24-3811
 Pipe Size: 8"
 Was the T/S located? YES / NO YES

TEST STATION CONDITION

Test Box:	<u>Good</u>
Terminal Board:	<u>Good</u>
Wires:	<u>Good</u>
Other:	

SURVEY DATA

Test Wire Size/Description	Color	P/Cu-CuSO ₄ (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1. #10 AWG	Blue	-0.983	-0.770	-0.882	-0.770	95
2. #8 AWG	Black	-0.044	0.044			
3. #10 AWG	Blue	-0.967	-0.763	-0.874	-0.767	
4. #6 AWG	Black	-0.978	-1.619	-0.893	-1.591	
5. #10 AWG	White	-0.705	-0.574	-0.517	-0.485	
6.						
7. #10 AWG	White	-0.716	-0.575	-0.608	-0.538	
8.						

P/Cu-CuSO₄ = Pipe to Copper-Copper Sulfate Reference Electrode

P/Zn = Pipe to Zinc Reference Electrode

"On" = Reading with Anode(s) connected

"Off" = Reading with Anode(s) disconnected

Anode = Current output Anode(s)

TESTING THE EFFECTIVENESS OF INSULATING JOINTS

Groundbed:			
Connected to (B/W):			
	Current (A)	Voltage (V)	Resistance (ohms)
ON:	0.02	0.235	2.0
OFF:	0.00	0.195	
DELTA:	0.02	0.040	

TESTING IR DROP

IR Drop Calibrations	I (A)	E (mV)	$K = \frac{\Delta I \text{ (mA)}}{\Delta E \text{ (mV)}}$	Between Terminals	Resistance (ohms)
INITIAL:					
FINAL:					
DELTA:					
			Direction:		

REPAIRS MADE

Test Box:	
Terminal Board:	
Wires:	
Other:	
Comments/Recommendations:	<u>IJ test confirms the electrical isolation between the two pipeline sections</u>



Figure 187 - Location of Test Station 3811-2



Figure 188 - Test Station 3811-2 close-up