

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
CORROSION CONTROL TEST STATION
FIELD DATA SURVEY FORM**

Location: 10+50 Date Surveyed: 06/01/2007
 T/S #: 3 Surveyed by: AS/MJ
 T/S Type: IR Contract #: 44-3327
 Pipe Size: 36"
 Was the T/S located? YES / NO _____

TEST STATION CONDITION

Test Box:	<u>Good</u>
Terminal Board:	<u>Good</u>
Wires:	<u>Good</u>
Other:	_____

SURVEY DATA

Test Wire Size/Description	Color	P/Cu-CuSO ₄ (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1. #10 AWG	Red	-1.520	-1.635	-0.436	-0.570	10.1
2. #10 AWG	Black	-1.482	-1.475	-0.431	-0.408	
3. #8 AWG	Orange	-1.483	-1.482	-0.435	-0.405	
4. #10 AWG	Green	-1.066	-1.081			
5.						
6. #12 AWG	Orange	-1.474	-1.083	-0.430	-0.407	
7. #6 AWG	Black	-1.491	-1.084	-0.426	-0.210	
8.						

P/Cu-CuSO₄ = Pipe to Copper-Copper Sulfate Reference Electrode
 P/Zn = Pipe to Zinc Reference Electrode
 "On" = Reading with Anode(s) connected
 "Off" = Reading with Anode(s) disconnected
 Anode = Current output Anode(s)

TESTING THE EFFECTIVENESS OF INSULATING JOINTS

Groundbed:	_____		
Connected to (B/W):	_____		
	Current (A)	Voltage (V)	Resistance (ohms)
ON:			
OFF:			
DELTA:			

TESTING IR DROP

IR Drop Calibrations	I (A)	E (mV)	K = $\frac{\Delta I \text{ (mA)}}{\Delta E \text{ (mV)}}$	Between Terminals	Resistance (ohms)
INITIAL:	0	0			
FINAL:	0.8	5.1	0.16		
DELTA:	-0.8	-5.1			

Direction: Orange-Black

REPAIRS MADE

Test Box:	_____
Terminal Board:	_____
Wires:	_____
Other:	_____
Comments/Recommendations:	_____



Figure 125 – Location of Test Station 3



Figure 126 – Test Station 3 close up