

HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
CORROSION CONTROL TEST STATION FIELD DATA SURVEY FORM

Cap Proj No : W-8169
Contract # : 44-3327
Location : Old Stockbridge Rd
T/S Type : ST/Anode
T/S Number : 13
Block Number : J09

Date Surveyed : 10/09/96
Surveyed by : R. Waldner/N. Powe
Pipe Type : Ductile Iron
Pipe Size : 36"
ADC Map # : 16
Tax Map Number :

TEST STATION CONDITION

Test Box : CP Flush Mounted
Terminal Board : Not present
Wires : Good
Other : No concrete pad

SURVEY DATA

Test Wire Size/Description	Color	P/Cu-CuSO4 (volts)		P/Zn (volts)		I anode (mA)
		"On"	"Off"	"On"	"Off"	
#10	Black	-1.353	-1.222	-.225	-.086	
#10 (Anode)	Red	-1.353	-1.767	-.225	-.631	54.000
#10 (Anode)	Red	-1.436	-1.320	-.308	-.184	
#10	Black	-1.351	-1.222	-.222	-.086	
#12 (Zn)	Green	-1.123	-1.135			

P/Cu-CuSO4 = Pipe to Copper-Copper Sulphate Reference Cell
P/Zn = Pipe to Zinc Permanent Reference Cell
"ON" = Reading with Anode(s) Connected
"OFF" = Reading with Anode(s) Disconnected
I anode = Current Output of Anodes

IR Drop Calibration

$$K = \frac{\Delta I \text{ (A)}}{\Delta E \text{ (mV)}} = \quad =$$

Direction :

REPAIRS MADE

Test Box: N/A
Wires: N/A
Board: N/A
Other: N/A
Comments: None