



Scale: 1" = 20'

NOTES

- Petition to the Board of Appeals, proposed Pump Island canopy permit application #55743 (pending)
- Owner: George A. Dezes PO Box 121 Chester, Maryland 21615
Applicant: Shell Oil Co
5565 Starrett Place
Columbia, Md 21044
- Existing zoning on subject property - B-1
- Property located in census tract 6064
- Zoning Map # 43, subject property is adjacent property zoned - B-1, also see B.A. case # 972.c.
- Located in community of Waterloo.
- Parking Required = 14
Shown = 14 spaces @ 10' x 21'
Requirement: 1 space per employee
1 space per accessory
3 spaces per bay
4 employees = 4 spaces
1 accessory vehicle = 1 space
3 bays = 9 spaces
Total = 14 spaces
- Number of employees = 12 total
4 persons per shift.

APPROVED
DIVISION OF LAND DEVELOPMENT
HOWARD COUNTY, MARYLAND
DATE: 3-1-79

APPROVED: For Public Water, Public Sewerage and Storm Drainage Systems and Roads
HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
 Director: *Clayton E. Nutter* 3-15-79
 Chief, Bureau of Engineering: *W. O. Lambert* 3-16-79
 APPROVED: For Public Water and Public Sewerage Systems
HOWARD COUNTY HEALTH DEPARTMENT
 County Health Officer: *John P. ...* 3-19-79
 APPROVED: Howard County Office of Planning and Zoning
 Planning Director: *Thomas J. ...* 3-20-79
 Chief, Division of Land Development: *...* 3-20-79

SITE DEVELOPMENT PLAN
 Property of
GEORGE A. DEZES
 0.8081 Acres
 Parcel A
 P.B. 21 F. 12
 Proposed Canopy Construction
 Elkridge (N. 1) District
 Howard County, Maryland

DESIGNED BY: *[Signature]* SCALE: 1" = 20' DATE: August, 1978 PHONE: 422-6080
 DRAWN BY: *[Signature]*
 APPROVED BY: *[Signature]*
 Light, Elliott, & Associates
 ENGINEERS PLANNERS SURVEYORS
 8508 ADELPHI ROAD - ADELPHI MARYLAND 20783
 JOB NO.: H.224
 FILE NO.: LG.1490

SDP 79-93

SDP-79-93