SEEDING NOTES
TEMPORARY SEEDING

APPLY TO GRADED OR CLEARED AREAS LIKELY TO BE REDISTURBED WHERE A SHORT-TERM VEGETATIVE COVER IS NEEDED.

SEEDBED PREPARATION: LOOSEN UPPER THREE INCHES OF SOIL BY RAKING, DISCING OR OTHER ACCEPTABLE MEANS BEFORE SEEDING.

SOIL AMENDMENTS: APPLY 600 LBS. PER ACRE 10-10-10 FERTILIZER (14 LBS./1000 SQ.FT.)

SEEDING: FOR PERIODS MARCH 1 THRU APRIL 30 AND FROM AUGUST 15 THRU NOVEMBER 15, SEED WITH 2 BUSHEL PER ACRE OF ANNUAL RYE (2.2 LBS./1000 SQ.FT.). FOR THE PERIOD MAY 1 THRU AUGUST 14, SEED WITH 3 LBS. PER ACRE OF WEEPING LOVEGRASS (.07 LBS. 1000 SQ.FT.). FOR THE PERIOD NOVEMBER 16 THRU FEBRUARY 28, PROTECT SITE BY APPLYING 2 TONS PER ACRE OF WELL ANCHORED STRAW MULCH AND SEED AS SOON AS POSSIBLE IN THE SPRING, OR USE SOD.

MULCHING: APPLY 1 TO 2 TONS PER ACRE (70 TO 90 LBS. 1000 SQ.FT.) OF UNROTTED SMALL GRAIN STRAW IMMEDIATELY AFTER SEEDING. ANCHOR MULCH IMMEDIATELY AFTER APPLICATION USING MULCH ANCHORING TOOL OR 218 GAL. PER ACRE (5 GAL./1000 SQ.FT.) OF EMULSIFIED ASPHALT ON FLAT AREAS, ON SLOPES, 8 FT. OR HIGHER, USE 348 GAL. PER ACRE (8 GAL./1000 SQ.FT.) FOR ANCHORING.

REFER TO THE 1983 MARYLAND STANDARDS AND SPECIFICATIONS FOR SOIL EROSION AND SEDIMENT CONTROL FOR RATE AND METHODS NOT COVERED.

PERMANENT SEEDING

APPLY TO GRADED OR CLEARED AREAS NOT SUBJECT TO IMMEDIATE FURTHER DISTURBANCE WHERE A PERMANENT LONG-LIVED VEGETATIVE COVER IS NEEDED

SEEDBED PREPARATION: LOOSEN UPPER THREE INCHES OF SOIL BY RAKING DISCING OR OTHER ACCEPTABLE MEANS BEFORE SEEDING.

SOIL AMENDMENTS: IN LIEU OF SOIL TEST RECOMMENDATIONS, USING ONE OF THE FOLLOWING SCHEDULES

1. GRADED - APPLY 2 TONS PER ACRE DOLOMITIC LIMESTONE (92 LBS. /1000 SQ.FT.) AND 600 LBS. PER ACRE 10-10-10 FERTILIZER (14 LBS. /1000 SQ.FT.) BEFORE SEEDING. HARROW OR DISC INTO UPPER THREE INCHES OF SOIL. AT TIME OF SEEDING, APPLY 400 LBS. PER ACRE 24-10-10 (UREAFORM) FERTILIZER (9 LBS. /1000 SQ.FT.)
2. ACCEPTABLE - APPLY 2 TONS PER ACRE DOLOMITIC LIMESTONE (92 LBS. /1000 SQ.FT.) AND 1000 LBS. PER ACRE 10-10-10 FERTILIZER (23 LBS. /1000 SQ.FT.) BEFORE SEEDING. HARROW OR DISC INTO UPPER THREE INCHES OF SOIL.

SEEDING - FOR THE PERIOD MARCH 1 THRU APRIL 30 AND AUGUST 1 THRU OCTOBER 15, SEED WITH 60 LBS. PER ACRE (1.4 LBS. /1000 SQ.FT. OF KENTUCKY 31 TALL FESCUE, FOR THE PERIOD MAY 1 THRU JULY 31, SEED WITH 60 LBS. KENTUCKY 31 TALL FESCUE PER ACRE AND 3 LBS. PER ACRE (.07 LBS. /1000 SQ.FT. OF WEEPING LOVEGRASS. DURING THE PERIOD OF OCTOBER 16 THRU FEBRUARY 28, PROTECT SITE BY OPTION (1) 2 TONS PER ACRE OF WELL ANCHORED STRAW MULCH AND SEED AS SOON AS POSSIBLE IN THE SPRING. OPTION (2) USE SOD. OPTION (3) SEED WITH 60 LBS. /ACRE KENTUCKY 31 TALL FESCUE AND MULCH WITH 2 TONS /ACRE WELL ANCHORED STRAW.

MULCHING - APPLY 1 TO 2 TONS PER ACRE (70 TO 90 LBS. 1000 SQ.FT.) OF UNROTTED SMALL GRAIN STRAW IMMEDIATELY AFTER SEEDING. ANCHOR MULCH IMMEDIATELY AFTER APPLICATION USING MULCH ANCHORING TOOL OR 218 GALLONS PER ACRE (5 GAL. /1000 SQ.FT.) OF EMULSIFIED ASPHALT ON FLAT AREAS, ON SLOPES 8 FT. OR HIGHER, USE 348 GALS. PER ACRE (8 GAL. 1000 SQ.FT. FOR ANCHORING.

MAINTENANCE - INSPECT ALL SEEDING AREAS AND MAKE NEEDED REPAIRS, REPLACEMENTS AND RESEEDINGS.

GENERAL NOTES

1. SPOT FIELD LOCATION OF EXISTING MAINS ARE SHOWN. THE CONTRACTOR SHALL TAKE ALL NECESSARY PRECAUTIONS TO PROTECT EXISTING MAINS AND SERVICES AND MAINTAIN UNINTERRUPTED SUPPLY. ANY DAMAGE INCURRED SHALL BE REPAIRED IMMEDIATELY TO THE SATISFACTION OF THE ENGINEER AT THE CONTRACTOR'S EXPENSE.
2. ALL HORIZONTAL CONTROLS ARE BASED ON MARYLAND STATE GRID COORDINATES.
3. ALL VERTICAL CONTROLS ARE BASED ON U.S.G.S. DATUM.
4. ALL PIPE ELEVATIONS SHOWN ARE INVERT ELEVATIONS UNLESS NOTED OTHERWISE.
5. CLEAR ALL UTILITIES BY A MINIMUM OF 6". CLEAR ALL POLES BY 2'-0" MINIMUM O.D. (UNLESS AS REQUIRED).
6. FOR DETAILS NOT SHOWN ON THE DRAWINGS, AND FOR MATERIALS AND CONSTRUCTION METHODS, USE HOWARD CO. DESIGN MANUAL, VOLUME IV, STANDARD SPECIFICATIONS AND DETAILS FOR CONSTRUCTION. THE CONTRACTOR SHALL HAVE A COPY OF VOLUME IV ON THE JOB.
7. EXISTING UTILITIES AS THE VICINITY OF THE PROPOSED WORK FOR WHICH TEST PITS HAVE NOT BEEN DUG SHALL BE LOCATED BY THE CONTRACTOR TWO WEEKS IN ADVANCE OF CONSTRUCTION OPERATIONS AT HIS OWN EXPENSE.
8. CONTRACTOR SHALL NOTIFY THE FOLLOWING UTILITIES OR AGENCIES AT LEAST FIVE WORKING DAYS BEFORE STARTING WORK SHOWN ON THESE PLANS:

STATE HIGHWAY ADMINISTRATION - 531-5533
BALTIMORE GAS & ELECTRIC CO. - CONTRACTOR SERVICES - 361-2585
BALTIMORE GAS & ELECTRIC CO. - UNDERGROUND DAMAGE CONTROL - 234-5021
BALTIMORE GAS & ELECTRIC CO. - TROUBLE SHOOTING - 398-5013
BELL UTILITY - 1-559-0100
COLONIAL PIPELINE CO. - 795-1390
BUREAU OF UTILITIES, HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS 992-3368

9. TREES AND SHRUBS ARE TO BE PROTECTED FROM DAMAGE TO MAINTAIN ENHANCE TREES AND SHRUBS LOCATED WITHIN THE CONSTRUCTION STRIPS ARE NOT TO BE REMOVED OR DAMAGED BY THE CONTRACTOR.
10. CONTRACTOR SHALL REMOVE TREES, STUMPS AND ROOTS ALONG LINE OF EXCAVATION.
11. ALL SEWER MAINS SHALL BE 8" D.I.P. CL. 52 UNLESS OTHERWISE NOTED.
12. THE CONTRACTOR SHALL PROVIDE A JOINT IN ALL SEWER MAINS WITHIN 2'-0" EXTERIOR MANHOLE WALL.
13. ALL MANHOLES SHALL BE 4'-0" INSIDE DIAMETER UNLESS OTHERWISE NOTED.
14. STRAW BALE DIKE AND SILT FENCE ARE INTERCHANGEABLE.

DATE	NO.	REVISION DESCRIPTION
4/14/89	1.	OMITTED SHEET 2 & ADDED PROFILES TO THIS SHEET.
3/19/90	2.	REV. WATER LINE TO BATH HOUSE M.C.R.

SEDIMENT CONTROL MEASURES FOR THIS CONTRACT WILL BE IMPLEMENTED IN ACCORDANCE WITH ARTICLE 15 OF THE STANDARD SPECIFICATIONS

FINAL PLAT 181-A, F89-140 SDP 89-125

REVIEWED FOR HOWARD SOIL CONSERVATION DISTRICT AND MEETS TECHNICAL REQUIREMENT

SIGNATURE John M. Klein DATE 5-9-89

U.S. SOIL CONSERVATION SERVICE

THIS DEVELOPMENT PLAN IS APPROVED FOR SOIL EROSION AND SEDIMENT CONTROL BY HOWARD COUNTY CONSERVATION DISTRICT

APPROVED

HOWARD S.C.D. Stephen P. Ebbert DATE 5/9/89

DEPARTMENT OF PUBLIC WORKS
HOWARD COUNTY, MARYLAND

DIRECTOR OF PUBLIC WORKS — DATE

CHIEF-BUREAU OF ENGINEERING — DATE 5/10/89

Robert W. Berning 5-6-89
CHIEF-BUREAU OF UTILITIES — DATE

CHIEF-LAND DEVELOPMENT DIVISION — DATE

NOTE:
30' WATER, SEWER & UTILITY EASEMENT SHOWN ON PLAT OF RESUBDIVISION OF LOT 146 AND PARCEL Q. SEE AMENDED FDP 181-A.

VILLAGE OF HICKORY RIDGE SECTION 3 AREA 1 PLAT # 2600





VICINITY MAP
SCALE: 1"=600'

NOTE: HELD 6" NORTH due TO EXCESSIVE TEMPERATURE AT STA. 0+00

PLAN
SCALE: 1"= 50'

WATER MAIN PROFILE
SCALES: 1"=50' HORZ. 1"=5' VERT.



NOTES:
1. ALL MANHOLES TO CONFORM TO HOWARD CO. STD. G5.11 EXCEPT AS NOTED.
2. ALL D.I. SEWER PIPE TO BE CLASS 52.

SEWER MAIN PROFILE
SCALES: 1"=50' HORZ. 1"=5' VERT.

STRUCTURE SCHEDULE

SANITARY

MANHOLE NO.	NORTHING	EASTING	INV. IN	INV. OUT	RIM ELEV.	VERT. DEPTH	TYPE	GRADE SLOPE	STD. DETAIL NO.
EX. MH 499	499713.7223	829064.0393	389.65	389.13	395.68	6.98	STD	2%	G5.11
1	499709.1789	829007.2212	390.87	390.87	405.90	15.83	STD	50%	G5.11
2	499741.2637	829004.6714	397.50	391.91	404.00	12.09	GRCP	50%	S1.32
3	499752.1756	828908.3973	404.41	404.21	419.00	14.79	STD	25%	G5.11
4	499708.8823	828854.0355	408.41	408.21	419.30	11.09	STD	2%	G5.11

WATER

FITTING NO.	NORTHING	EASTING	DESCRIPTION	LOCATION	STD. DETAIL NO.
1	499750.54.6	829047.084	8" TAPPING SLEEVE & VALVE	EX. 8" WATER	#2.23
2	499749.059	829024.860	11 1/4° (1/32) BEND	TEMPORARY LINE	#2.21
3	499768.806	828993.2269	45° (1/8) BEND	OPPOSITE SMH 3	#2.21
4	499754.9655	828889.2265	8"x6" TEE	FIRE HYDRANT	#1.11
5	499728.2928	828849.0295	8"x6" REDUCER	SMH 4	
6	499713.6040	828837.4914	6" CAP & PLUG	SMH 4	

QUANTITIES BOX

ITEM	ESTIMATED	AS-BUILT	MATERIAL/SUPPLIER
SEWER MANHOLE	NO: 4	4	DEWEY BRO. / BRS
8" SEWER	696 L.F.	240 LF	ATLANTIC CO / ASP
6" SEWER	68 L.F.	18	"
8" WHC	18LF	20 LF	ATLANTIC / ASP JOINT
6" VALVE (EXCLUDING F.H. VALVE)	NO: 1	1	TYLER PIPE / ASP
FIRE HYDRANTS	NO: 1	1	MUELLER / ASP
8" TAPPING SLEEVE & VALVE	NO: 1	1	MUELLER
8" WATER	213 LF	215	ATLANTIC CO / ASP
2" WATER	20 LF	21	"
3" WHC	20 LF		


PROPOSED 8" WATER LINE
EX. 8" WATER
EX. 8" SEWER
PROPOSED 8" SEWER
EX. 6" SEWER
EX. 8" WATER
EX. 6" WATER
EX.