



NOTICE

WATER MAIN TO HAVE A MINIMUM OF 40 FT. OF COVER.
 ALL LEAD JOINTS.

CONTRACTOR TO MAKE THE CONNECTION TO THE EXISTING
 6" WATER MAIN, UNDER THE SUPERVISION OF THE
 BUREAU OF WATER SUPPLY OF BALTO. CITY.

ALL BENDS, TEES, CAPS AND THE FIRE HYDRANT, MUST
 BE BLOCKED WITH A CONCRETE BUTTRESS.

LIST OF PIPE FITTINGS		
NO.	DESCRIPTION	SIZE
2	TEES	6"
1	1/2" BEND	6"
1	1/2" BEND	6"
3	CAPS	6"
1	1/2" BLOWOFF	6"
2	VALVES	6"
1	S.N.F.H.D.	6"

C.W.O. 16942

ELKRIDGE WATER DISTRICT
 HOWARD COUNTY, MARYLAND

777.5 FT. OF 6" WATER MAIN
 CENTRIFUGAL PIPE - CLASS 150 -
 REVISED AS PER RECORD PLAN, JUNE 10, 1941.

PLANS PREPARED BY
Charles B. Wiles

APPROVED BY COUNTY COMMISSIONERS
 DATE *JAN. 2, 1941*
Robert H. Miller

APPROVED FOR CITY OF BALTIMORE
 DATE *Jan. 6, 1941*
George Cobb
 WATER ENGINEER CHIEF ENGINEER

PROPOSED WATER MAIN IN WASHINGTON
 BOULEVARD FROM MONTGOMERY ROAD
 NORTHERLY

DRAWING NO. *1* OF *1*
 SCALE 1" = 50'
 4000'

W105° 33' 21"