

Howard County Pipe Break Field Data

	Location and Contact information		
Date	6-27-12	Time	11:00am
Crew Leader name	Duane Bozzell	Crew Leader phone #	410-313-4500
Address	10730 Evening Wind Ct		
ADC page	4935	ADC Grid	A-5
Base Map #	2740	Contract #	2009 166w-s

Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	<input checked="" type="checkbox"/>
Sand		Blue/gray clay	
Silt			

Pipe Type

Type	Check box	Type	Check box
Cast iron	<input checked="" type="checkbox"/>	PCCP/Concrete	
Ductile iron		Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

Type of Break

Type	Check box	Type	Check box
Circular	<input checked="" type="checkbox"/>	Damage by others	
Split	<input checked="" type="checkbox"/>	Pipe Joint leak	
Fitting leak		Valve problem	

Size of Pipe

Size in inches	6
----------------	---