

Howard County Pipe Break Field Data

Location and Contact information			
Date	11/17/12	Time	8:30 pm
Crew Leader name	Chuck Carroll	Crew Leader phone #	410-313-4900
Address	9424 Madison Ave Laurel MA 20723		
ADC page	5169	ADC Grid	F3
Base Map #	1741	Contract #	1W B 15

Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	<input checked="" type="checkbox"/>
Sand		Blue/gray clay	
Silt			

Pipe Type

Type	Check box	Type	Check box
Cast iron	<input checked="" type="checkbox"/>	PCCP/Concrete	
Ductile iron		Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

Type of Break

Type	Check box	Type	Check box
Circular	<input checked="" type="checkbox"/>	Damage by others	
Split		Pipe Joint leak	
Fitting leak		Valve problem	

Size of Pipe

Size in inches	6
----------------	---

Repaired with six-inch full circle clamp