

Howard County Pipe Break Field Data

Location and Contact information			
Date	10-27-12	Time	
Crew Leader name	Duane Bozzell	Crew Leader phone #	410-313-4900
Address	9731 Washington BLVD		
ADC page	5169	ADC Grid	H-01
Base Map #	1842	Contract #	1-W

Soil Type

Type	Check box	Type	Check box
Clay		Clay/sand	<input checked="" type="checkbox"/>
Sand		Blue/gray clay	
Silt			

Pipe Type

Type	Check box	Type	Check box
Cast iron	<input checked="" type="checkbox"/>	PCCP/Concrete	
Ductile iron		Plastic PVC	
Steel		Plastic polyethylene	
AC/Transite			

Type of Break

Type	Check box	Type	Check box
Circular		Damage by others	
Split	<input checked="" type="checkbox"/>	Pipe Joint leak	
Fitting leak		Valve problem	

Size of Pipe

Size in inches	8"
----------------	----