

Mission Road Investors, LLC
Mission Place Water and Sewer Mains
Howard County, Maryland

Russell Corrosion Consultants, Inc.
RCC Project #769
June, 2007

TABLE A-2
Stray Current (Potential) Data

Location	GPS Coordinates		Structure Tested	DC Potential (Volts)	AC Potential (Volts)
	Latitude	Longitude			
Rt. 1 at N. Roberts Rd.	N 39° 09' 50.9"	W -076° 47' 31.8"	Fire Hydrant	0.52	0.01
Rt. 1 Opposite #8145	N 39° 09' 46.7"	W -076° 47' 35.5"	AC Ground	0.34	0.15
Mission Road at BGE Rectifier	N 39° 09' 45.1"	W -076° 47' 41.7"	AC Ground	-2.64	1.16
N. Roberts Rd. 475' West of Rt. 1	N 39° 09' 52.9"	W -076° 47' 35.2"	AC Ground	0.54	0.01