

Date: 6/15/94


Time: 9:30A - 12:30P

Effective Groundbed Width (ft): 200

Stray Current Shifts (mV): DC 73mV;

Comments: Near Colonial Gas Line Crossing (Sta. 129+00)

Figure 24. Stray Current Survey (AM) for Site 6



Date: 6/15/94

Time: 12:45P - 4:00P

Effective Groundbed Width (ft): 200

Stray Current Shifts (mV): DC 19mV;

Comments:

Figure 25. Stray Current Survey (PM) for Site 6