

Date: 6/16/94


Time: 9:15A - 12:15P

Effective Groundbed Width (ft): 200

Stray Current Shifts (mV): DC 60mV;

Comments: Near MH 8478 (Sta. 139+26)

Figure 26. Stray Current Survey (AM) for Site 7



Date: 6/16/94

Time: 12:20P - 2:15P

Effective Groundbed Width (ft): 200

Stray Current Shifts (mV): DC 141mV;

Comments: Severe electrical storm starting at approx. 1:30P

Figure 27. Stray Current Survey (PM) for Site 7



Figure 7. Location of Site 7



Figure 8. Location of Site 9