

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS  
CORROSION CONTROL TEST STATION  
FIELD DATA SURVEY FORM**

**Location:** Cedar Ave. & Georgia Ave. **Date Surveyed:** 3/22/2005  
**T/S #:** 03 **Surveyed by:** AC/MJ  
**T/S Type:** ST w/ Anode **Contract #:** 24-3811  
**Pipe Size:** 8"

**Was Test Station located? YES/NO** Yes

**TEST STATION CONDITION**

**Test Box :** Covered by Soil and Filled with Water  
**Terminal Board :** Good  
**Wires :** Good  
**Other :** \_\_\_\_\_

**SURVEY DATA**

Test Wire Size/Description	Color	P/Cu-CuSO <sub>4</sub> (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1) #10	Blue	-1.112	-0.869	-0.839	-0.760	326.0
2)						
3) #10	Blue	-1.108	-0.870	-0.783	-0.754	
4) #6	Black	-1.116	-1.728	-0.774	-1.611	
5)						
6)						
7) #8	Black	-0.161	-0.112			

P/Cu-CuSO<sub>4</sub> = Pipe to Copper - Copper Sulfate Reference Cell  
P/Zn = Pipe to Zinc Permanent Reference Cell  
"On" = Reading with Anode(s) connected  
"Off" = Reading with Anode(s) disconnected  
I Anode = Current output of anodes

**REPAIRS MADE**

**Test Box:** \_\_\_\_\_  
**Terminal Board:** \_\_\_\_\_  
**Wires:** \_\_\_\_\_  
**Other:** \_\_\_\_\_  
**Additional Comments/Recommendations:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



**Figure 201 - Location of Test Station 3811-3**



**Figure 202 - Test Station 3811-3 close-up**