HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS CORROSION CONTROL TEST STATION FIELD DATA SURVEY FORM

TIEED DATA GORVET FORM								
Location:	5' S. of MD	108/ MD 32	Bridge	Date Surveyed	i : 05/30	05/30/2007		
				Surveyed by:	AS/M	AS/MJ		
T/S #:			Contract #:		44-3231			
T/S Type:	01 IJ			Pipe Size:	12"			
Was the T/S located? YES / NO YES				1 lpe 312e.	12			
TEST STATION CONDITION								
Test Box: Good								
Terminal Board: Good								
Wires: Good								
Other:								
SURVEY DATA								
Test Wire			P/Cu-CuSO ₄ (V)		P/Zn (V)		Anode	
Size/Des		Color		"On""Off"	"O	n""Off"	(mA)	
1. #10 A		Black		-0.103				
2. #10 /	AWG	Black		-1.180		-1.077		
3. #10 A	AWG	Green		-0.745		-0.706		
4. #10 A	AWG	Black		-1.115		-1.077		
5. #10 A	AWG	Black		-0.655		-0.601		
6. #10 A		Green		-0.760		-0.707		
7.		010011						
8.								
P/Cu-CuSO ₄ = Pipe to Copper-Copper Sulfate Reference Electrode								
P/Zn = Pipe to Zinc Reference Electrode								
"On" = Reading with Anode(s) connected								
"Off" = Reading with Anode(s) disconnected								
Anode = Current output Anode(s)								
TESTING THE EFFECTIVENESS OF INSULATING JOINTS								
Groundbed:								
Connected to (B/W):								
Current (A)				Voltage (V)	1	Resistance (ohms)		
ON:	5.28			10111.90 (1)	10.4	2		
OFF:	0.000				-0.43			
DELTA:			5.28		10.8			
DELIA.					10.0			
TESTING IR DROP								
IR Drop						Between	Resistance	
Calibrations		E (1	nV)		∆I (m A)	Terminals	(ohms)	
INITIAL:	:			Δ	E (mV)			
FINAL:	:							
DELTA:	:			Direction:				
REPAIRS MADE								
Test Box:								
Terminal Board:								
Wires:								
Other:	· · · · · ·	. ()	114. 41	Jr (. J . # . #	.1.0. 60			
Comments/Recommendations: IJ test indicated effective isolation of the two pipes.								



Figure 103 - Location of Test Station 3231-1



Figure 104 - Test Station 3231-1 close-up