

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS
CORROSION CONTROL TEST STATION
FIELD DATA SURVEY FORM**

Location: 63+00 Date Surveyed: 06/05/2007
E. of Old Stockbridge & Old field Surveyed by: AS/MJ
 T/S #: 13 Contract #: 44-3327
 T/S Type: ST w/Anode Pipe Size: 36"
 Was the T/S located? YES / NO Yes

TEST STATION CONDITION

Test Box:	<u>Water inside</u>
Terminal Board:	<u>Good</u>
Wires:	<u>Good</u>
Other:	

SURVEY DATA

Test Wire Size/Description	Color	P/Cu-CuSO ₄ (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1. #8 AWG	Red	-1.325	-1.665	-0.306	-0.623	48.5
2.						
3. #10 AWG	Black	-1.387	-1.190	-0.307	-0.139	
4. #10 AWG	Green	-1.082	-1.058			
5.						
6. #10 AWG	Black	-1.357	-1.217	-0.303	-0.133	
7.						
8.						

P/Cu-CuSO₄ = Pipe to Copper-Copper Sulfate Reference Electrode

P/Zn = Pipe to Zinc Reference Electrode

"On" = Reading with Anode(s) connected

"Off" = Reading with Anode(s) disconnected

Anode = Current output Anode(s)

TESTING THE EFFECTIVENESS OF INSULATING JOINTS

Groundbed:			
Connected to (B/W):			
	Current (A)	Voltage (V)	Resistance (ohms)
ON:			
OFF:			
DELTA:			

TESTING IR DROP

IR Drop Calibrations	I (A)	E (mV)	$K = \frac{\Delta I \text{ (mA)}}{\Delta E \text{ (mV)}}$	Between Terminals	Resistance (ohms)
INITIAL:					
FINAL:					
DELTA:					
			Direction:		

REPAIRS MADE

Test Box:	
Terminal Board:	
Wires:	
Other:	
Comments/Recommendations:	



Figure 145 – Location of Test Station 13



Figure 146 – Test Station 13 close up