

**HOWARD COUNTY DEPARTMENT OF PUBLIC WORKS  
CORROSION CONTROL TEST STATION  
FIELD DATA SURVEY FORM**

Location: 00+00 Date Surveyed: 06/21/2007  
 T/S #: 1 Surveyed by: AS/MJ  
 T/S Type: IJ w/Anode Contract #: 44-4227  
 Pipe Size: 48"  
 Was the T/S located? YES / NO YES

**TEST STATION CONDITION**

Test Box: Above ground  
 Terminal Board: 7 terminals in good condition  
 Wires: Good  
 Other: \_\_\_\_\_

**SURVEY DATA**

Test Wire Size/Description	Color	P/Cu-CuSO <sub>4</sub> (V)		P/Zn (V)		Anode (mA)
		"On"	"Off"	"On"	"Off"	
1. #2 W. Anodes	Black	-0.998	-0.805	-0.322	-0.319	10
2. #2 E. Anodes	Black	-0.992	-0.955	-0.284	-0.320	
3. #2 N. Pipe	White	-0.875	-0.894	-0.473	-0.381	
4. #2 S. Pipe	Black	-0.800	-0.811	-0.464	-0.470	
5. #8 Reference	Black	-1.225	-1.249			
6. #8 N. Pipe	White	-0.802	-0.892	-0.472	-0.470	
7. #8 S. Pipe	Black	-0.887	-0.887	-0.381	-0.380	
8.						

P/Cu-CuSO<sub>4</sub> = Pipe to Copper-Copper Sulfate Reference Electrode

P/Zn = Pipe to Zinc Reference Electrode

"On" = Reading with Anode(s) connected

"Off" = Reading with Anode(s) disconnected

Anode = Current output Anode(s)

**TESTING THE EFFECTIVENESS OF INSULATING JOINTS**

Groundbed: \_\_\_\_\_  
 Connected to (B/W): \_\_\_\_\_

	Current (A)	Voltage (V)	Resistance (ohms)
ON:	0.120	0.557	3.89
OFF:	0.000	0.090	
DELTA:	0.120	0.467	

**TESTING IR DROP**

IR Drop Calibrations	I (A)	E (mV)	K = $\frac{\Delta I \text{ (mA)}}{\Delta E \text{ (mV)}}$	Between Terminals	Resistance (ohms)
INITIAL:					
FINAL:					
DELTA:					

Direction: \_\_\_\_\_

**REPAIRS MADE**

Test Box: \_\_\_\_\_  
 Terminal Board: \_\_\_\_\_  
 Wires: \_\_\_\_\_  
 Other: \_\_\_\_\_  
 Comments/Recommendations: Some of the plastic washers used in the terminal board were obstructing anode/pipe electrical contact. They were removed.



Figure 230 - Location of Test Station 4227-1



Figure 231 - Test Station 4227-1 close-up