





PERCOLATION TEST DATA

Lot No.	Average percolation time in minutes per 2nd inch	Maximum depth permitted for effluent pipe to enter sewage disposal area at its highest elevation with reference to the existing grade at the time of Perc.	Comments
1	19.6 min.	5'-0"	*
2	4.75 min.	4'-0"	*
3	13.75 min.	4'-6"	*
4	7.75 min.	5'-0"	*
5	4.50 min.	4'-0"	*
6	4.00 min.	4'-0"	*
7	2.55 min.	5'-0"	*
8	3.00 min.	4'-0"	*
9	3.75 min.	4'-6"	*
10	4.00 min.	4'-6"	*
11			
12	3.50 min.	5'-0"	*
13	5.75 min.	5'-0"	*
14	5.85 min.	5'-0"	*
15	16.50 min.	5'-6"	* COMBINE 14/15
16	5.85 min.	4'-6"	*
17	1.65 min.	4'-0"	*
18	9.25 min.	5'-0"	*
19	12.25 min.	4'-6"	*
20	15.50 min.	5'-0"	*
21	9.50 min.	4'-0"	*
22	2.85 min.	4'-0"	*
23			

Note: * = Shallow System



VICINITY MAP
SCALE 1" = 2000'



TENTATIVELY APPROVED ON Nov 26, 1985
OFFICE OF PLANNING AND ZONING OF HOWARD COUNTY
PLANNING DIRECTOR
DATE



SURVEYOR'S CERTIFICATE
I HEREBY CERTIFY THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF THE INFORMATION SHOWN HEREON IS CORRECT.
DATE 12-4-85
OFFICER D. LAWRENCE
MD. REG. PROF. L.S. 3216

Approved for Private water supply & sewage disposal systems - Howard County Department of Environmental Health.
County Health Officer
DATE 11-20-85

- GENERAL NOTES
- AREA OF PROPERTY = 75.5 ac
 - PROPERTY ZONED = R (3 ac min)
 - PROPERTY FOUND ON TAX MAP 34 PARCELS 75 & 318
 - PROPERTY FOUND ON HOWARD COUNTY MAP 28
 - DEED REFERENCE = LIBER, 1231 FOLIO 038
 - NUMBER OF LOTS = 22
 - AREA OF LOTS = 71.72 ac
 - AVERAGE LOT AREA = 3.26 ac
 - SETBACKS: FRONT = 50' STREET SIDE = 30' LOT REAR 60'
 - THIS AREA DESIGNATES A PRIVATE SEWAGE EASEMENT OF 10,000 S.F. AS REQUIRED BY THE MARYLAND STATE DEPARTMENT OF HEALTH & MENTAL HYGIENE FOR INDIVIDUAL SEWAGE DISPOSAL. IMPROVEMENTS OF ANY NATURE IN THIS AREA ARE RESTRICTED UNTIL PUBLIC SEWAGE IS AVAILABLE. THESE EASEMENTS SHALL BECOME NULL AND VOID UPON CONNECTION TO A PUBLIC SEWAGE SYSTEM. THE COUNTY HEALTH OFFICER SHALL HAVE THE AUTHORITY TO GRANT VARIANCES FOR ENCROACHMENTS INTO THE PRIVATE SEWAGE EASEMENT. RECONSTRUCTION OF A MODIFIED SEWAGE EASEMENT SHALL NOT BE NECESSARY. PERCOLATION TEST HOLES SHOWN HEREON HAVE BEEN FIELD LOCATED AS SHOWN.
 - THE LOTS SHOWN HEREON COMPLY WITH THE MINIMUM OWNERSHIP WIDTH AND LOT AREAS AS REQUIRED BY THE MARYLAND STATE DEPARTMENT OF HEALTH AND MENTAL HYGIENE.
 - SEE SHEET 2 OF 3 FOR DRAINAGE STUDY & 3 OF 3 FOR STREET GRADERS.

Owner: CONTRACT

NO.	REVISIONS	DATE

HIGHLAND ASSOCIATES
P.O. BOX 208
CLARKSVILLE, MD. 21027
301-591-5227



DEVELOPMENT CONSULTANTS GROUP, INC.
17904 GEORGIA AVENUE SUITE 102
OLNEY, MARYLAND 20832
301-924-4570

PRELIMINARY PLAN
GREENE FIELDS
ELECTION DISTRICT No 5
TAX MAP 34 PARCEL 75 & 318
HOWARD COUNTY, MARYLAND

DATE OCT. 1985	Sheet 1
DRAWN MIKEL	of 1
CHECKED M.L.G.	PROJECT NO. 136-01
SCALE 1" = 100'	