



VICINITY MAP
Scale: 1" = 1/2 mile

GENERAL NOTES

1. Approximate locations of existing mains are shown. The Contractor shall take all necessary precautions to protect existing mains and services and maintain uninterrupted supply. Any damage incurred shall be repaired immediately.
2. All pipe elevations shown are invert elevations.
3. The Contractor shall test pit existing utilities, which will be encountered during construction, a minimum of two weeks in advance of operations.
4. For all standard details see standards bound in Specifications.
5. All water mains to be C.I.P. or D.I.P. and have a minimum of 3 1/2' cover.
6. Block all fittings with concrete see standard details bound in Specifications.
7. Bury line elevations on fire hydrants shall be set the same as edge of paving, top of curb, or as directed by the Engineer in the field.
8. All Fire Hydrants shall be buttressed with concrete in accordance with Standard Detail W-4.
9. Clear all utilities by a minimum of 6', clear all poles by 20' minimum or tunnel as required.



No.	Date	Revision
1		Added 12" Valve

WHITMAN, REQUARDT & ASSOCIATES ENGINEERS 1304 ST. PAUL ST. BALTIMORE, MARYLAND	HOWARD COUNTY METROPOLITAN COMMISSION DATE: 9-15-67 CHIEF ENGINEER: [Signature]	CONTRACT NO. 198-W	PLAN OF WATER MAINS	ELECTION DISTRICT ELKRIDGE NO.1	DRAWING NO. 1 OF 2 SCALE: 1" = 50'
---	---	--------------------	------------------------	------------------------------------	---------------------------------------

Old Montgomery Road
Contract US 198-W

W. O. 5859-2

AS BUILT AUGUST 29, 1969 FD.5914

1/W-81/1
SM

