



- GENERAL NOTES**
1. All horizontal and vertical controls are based on Maryland State Datum.
 2. All water mains shall have a minimum of 3.5' cover.
 3. Approximate location of existing mains are shown. The Contractor shall take all necessary precautions to protect existing mains and services and maintain uninterrupted supply. Any damage incurred shall be repaired immediately.
 4. All elevations shown are invert elevations.
 5. The Contractor shall locate existing utilities a minimum of two weeks in advance of construction operations in vicinity of utilities.
 6. For all standard details, see standards found in specifications.
 7. Block all fittings with concrete. See Howard County Spec. Book.
 8. Clear all utilities by a minimum of 6", all poles by 2' minimum or tunnel as required.

Contract No. 620-W
 First Street
 North Laurel Park
 Water Main Extension

BUREAU OF ENGINEERING INSPECTION & SURVEY	DEPARTMENT OF PUBLIC WORKS HOWARD COUNTY, MARYLAND DATE: 6-20-74 [Signature]	CONTRACT NO. 620-W	PLAN OF WATER MAINS	PATUXENT SUB-DISTRICT	DRAWING NO. 1 OF 1	SCALE AS SHOWN	Des. M.A.W. Chk. J.L.R. Draw. J.O.C. Draw. J.D.H.