



NEW WASH. BLVD.

(MONROE CLAY COLONNA)

(MONROE CLAY COLONNA)

400 FT - 8 IN. CLASS 250 PIPE

Revised according to Record Print
DATE 7/19/50 BY THE WILSON T. BALLARD CO.

C.W.O. 23372

NOTE:
Water Main to have a minimum of 3 1/2 Ft. cover.
All joints of Lead
All fittings to be blocked with Concrete Buttress
Right of Way obtained by Howard County.

LIST OF FITTINGS		
NO.	DESCRIPTION	SIZE
1	Cap	8"
1	Blow-off	1 1/2"

3/28/50
JEB

APPROVED FOR HOWARD COUNTY
CHAIRMAN

HOWARD COUNTY METROPOLITAN COMMISSION
ELKRIDGE, HOWARD COUNTY MARYLAND

APPROVED FOR BALTO. CITY
3-28-50.
WATER ENGR. CHIEF ENGR.

PLAN PREPARED BY:-
THE

PROPOSED WATER MAIN EXTENSION
IN PINE AVE

SCALE
1" = 50'